



EC Type Examination Certificate Number: **0120/SGS0130**

Owen Brothers Metering UK Ltd

Unit 6 Glen Trading Estate
Wellyhole Street
Oldham
OL4 3BF

Instrument Identification:
OB737

Instrument Traceable Number
0120/SGS0130

Poly Phase, Active Import/ Export, Indoor, Electricity Meter

has been assessed and certified as meeting the requirements of

EC Directive 2004/22/EC **Measuring Instruments Annex B**

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of MI-003 of EC Directive 2004/22/EC

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex D or Annex F.

This certificate is valid for 10 years from 6th June 2013 to 5th June 2023
Issue 1


Certification is based on report number(s) SHES130300061001 dated 3rd June 2013

Authorised Signature

Jan Saunders


SGS United Kingdom Limited, Notified Body 0120
Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA UK
t +44 (0)1934 522917 f +44 (0)1934 522137 www.sgs.com

Contact Address
SGS United Kingdom Ltd, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD UK
t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sgs.com

| | | |
|---|---|-------------------------------------|
|  | EC-Type Examination Certificate Number: | |
| | 0120/ SGS0130 | |
| | Issue Number: 1 | Dated: 12 th August 2013 |


1. Technical Data

| | |
|--|-------------------------------------|
| Manufacturer | Owen Brothers Metering UK Ltd |
| Meter Type | OB737 |
| Voltage Rating (U_n) | 3x230/400V |
| Current Rating ($I_{min} - I_{ref} (I_{max})$) | 0.5-10(100)A |
| Frequency (F_n) | 50Hz |
| Active Accuracy Class (kWh) | A or B (kWh) |
| Type of circuit | 3p4w |
| Temperature Range | -25°C to +55°C |
| Software Version No. | 0737.00.03 |
| Identification Location | LCD |
| Bill Of Materials No.'s | FQ-JS-001-007 |
| IP Rating | IP51 |
| Insulation Protective Class | Class II |
| LED Pulse Constant | 400 imp/ kWh |
| Impulse Voltage Rating | 6kV |
| AC Voltage Rating | 4kV |
| Main Cover Sealing Type | 4 x Wire & Crimp |
| Integrity of meter | Inaccessible without breaking seals |
| Intended Location of the Meter | Indoor |
| Type of Register | LCD |
| Terminal Arrangement(s) | BS |

| | | |
|---|---|-------------------------------------|
|  | EC-Type Examination Certificate Number: | |
| | 0120/ SGS0130 | |
| | Issue Number: 1 | Dated: 12 th August 2013 |

2. Photograph of Meter and Sealing Plan



| | | |
|---|---|-------------------------------------|
|  | EC-Type Examination Certificate Number: | |
| | 0120/ SGS0130 | |
| | Issue Number: 1 | Dated: 12 th August 2013 |

3. Influence factors for temperature, frequency and voltage


| Influence Factors for temperature, frequency and voltage | | | | | | | |
|--|--------|-------------|-------------|-------------|-------------|-------------|-------------|
| Current | PF Cos | -25 | -10 | 5 | 30 | 40 | 55 |
| I _{min} | 1.0 | 0.00 | 0.10 | 0.01 | 0.01 | 0.21 | 0.02 |
| I _{tr} | 1.0 | 0.03 | 0.08 | 0.02 | 0.01 | 0.10 | 0.02 |
| 10I _{tr} | 1.0 | 0.11 | 0.10 | 0.02 | 0.21 | 0.21 | 0.20 |
| I _{max} | 1.0 | 0.18 | 0.17 | 0.02 | 0.02 | 0.07 | 0.06 |
| | | | | | | | |
| I _{tr} | 0.5ind | 0.01 | 0.08 | 0.09 | 0.06 | 0.18 | 0.32 |
| 10I _{tr} | 0.5ind | 0.04 | 0.07 | 0.02 | 0.19 | 0.04 | 0.01 |
| I _{max} | 0.5ind | 0.27 | 0.24 | 0.26 | 0.25 | 0.34 | 0.24 |
| | | | | | | | |
| I _{tr} | 0.8cap | 0.02 | 0.03 | 0.17 | 0.02 | 0.17 | 0.27 |
| 10I _{tr} | 0.8cap | 0.05 | 0.05 | 0.02 | 0.19 | 0.04 | 0.11 |
| I _{max} | 0.8cap | 0.04 | 0.04 | 0.31 | 0.04 | 0.04 | 0.05 |

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below presents the sum of the square values per load, determined via the following formula:-

$$\delta e(T, U, f) = \sqrt{(\delta e^2(T, I, \cos\varphi) + \delta e^2(U, I, \cos\varphi) + \delta e^2(f, I, \cos\varphi))}$$

where

$\delta e(T, I, \cos\varphi) =$ Additional error due to variation of the temperature at the same load
 $\delta e(U, I, \cos\varphi) =$ Additional error due to variation of the voltage at the same load
 $\delta e(f, I, \cos\varphi) =$ Additional error due to variation of the frequency at the same load

| | | |
|---|---|-------------------------------------|
|  | EC-Type Examination Certificate Number: | |
| | 0120/ SGS0130 | |
| | Issue Number: 1 | Dated: 12 th August 2013 |

4. Annex of Variants

Product Variant Identification Details:

| Type Designation | Description of meter |
|---|----------------------|
| OB737 0,5-10(100)A – Poly Phase, Active Import/Export kWh, Multifunction, Electricity Meter | |

Modifications to the meter(s) described according to approval No. **0120/SGS0130** must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).

5. Document Revision History

| Issue | Date | Comments |
|-------|------------|---------------|
| 1 | 12/08/2013 | Initial Issue |
| | | |